

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
 (ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Apr-20  
 ISSUE TIME: 10:00 Hrs  
 FOR DATE: 27-Apr-20

Daily Plant Report  
 (00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Apr-20	0:00:00	27-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 28.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Apr-20	0:00:00	27-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	27-Apr-20	17:30:00	27-Apr-20	24:00:00	6:30:00	37.00	0.241	
4	27-Apr-20	0:00:00	27-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	27-Apr-20	0:00:00	27-Apr-20	9:00:00	9:00:00	38.00	0.331	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Apr-20	5:45 22:45	27-Apr-20	8:15 24:00	3:45:00	164	0.610	Today(i.e. 28.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	27-Apr-20	6:00 22:30	27-Apr-20	8:30 24:00	4:00:00	164	0.654	
3	27-Apr-20	0:00 5:30 22:15	27-Apr-20	1:45 8:45 24:00	6:45:00	165	1.110	
4	27-Apr-20	5:00 22:00	27-Apr-20	9:00 24:00	6:00:00	165	0.994	
5	27-Apr-20	0:00:00	27-Apr-20	1:15:00	1:15:00	165	0.210	
6	27-Apr-20	0:00 5:15	27-Apr-20	1:30 9:15	5:30:00	164	0.906	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.572	4.484	5.056
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		46.739	121.484	168.223
PREVIOUS DAY ACTUAL RUNNING HOURS		15:30:00	27:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	28:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	28:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Apr-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 120.92 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9666 Cusec 24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10566 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3026	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3023	3415	7151	581



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL

AEE (EMC)  
 NCA, INDORE