

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 28-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Apr-20	0:00:00	28-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 29.04.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	28-Apr-20	0:00:00	28-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	28-Apr-20	0:00:00	28-Apr-20	8:30:00	8:30:00	37.00	0.312	
4	28-Apr-20	0:00:00	28-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	28-Apr-20	17:30:00	28-Apr-20	24:00:00	6:30:00	37.00	0.238	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Apr-20	0:00 5:15 22:30	28-Apr-20	0:45 8:00 24:00	5:00:00	164	0.824	Today(i.e. 29.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	28-Apr-20	0:00 5:30 23:00	28-Apr-20	1:00 8:00 24:00	4:30:00	164	0.744	
3	28-Apr-20	0:00 6:00	28-Apr-20	1:15 8:15	3:30:00	164	0.574	
4	28-Apr-20	0:00 5:45	28-Apr-20	1:30 8:30	4:15:00	164	0.706	
5	28-Apr-20	18:45:00	28-Apr-20	24:00:00	5:15:00	164	0.862	
6	28-Apr-20	5:00 22:15	28-Apr-20	8:45 24:00	5:30:00	164	0.898	

GROSS GENERATION IN(MUs)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		0.550	4.608	5.158
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		47.289	126.092	173.381
PREVIOUS DAY ACTUAL RUNNING HOURS		15:00:00	28:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	28:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	26:30:00	

SSP hydrological data - at 08:00 Hrs on 29-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.89 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8905 Cusec 22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10546 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3023	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3736	3295	7251	580



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL.