

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Apr-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 29-Apr-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Apr-20	0:00:00	29-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 30.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Apr-20	0:00:00	29-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	29-Apr-20	0:00:00	29-Apr-20	0:00:00	0:00:00	0.00	0.000	
4	29-Apr-20	0:00:00	29-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	29-Apr-20	0:00:00	29-Apr-20	24:00:00	24:00:00	38.00	0.880	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Apr-20	0:00 5:15	29-Apr-20	1:45 8:00	4:30:00	164	0.736	Today(i.e. 30.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	29-Apr-20	0:00 5:30 22:15	29-Apr-20	0:45 8:15 24:00	5:15:00	164	0.856	
3	29-Apr-20	06:00 22:30	29-Apr-20	8:45 24:00	4:15:00	163	0.696	
4	29-Apr-20	0:00:00	29-Apr-20	0:00:00	0:00:00	0	0.000	
5	29-Apr-20	0:00 5:45	29-Apr-20	0:30 8:30	3:15:00	162	0.538	
6	29-Apr-20	0:00 5:00 18:45	29-Apr-20	2:00 8:30 24:00	10:45:00	165	1.772	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.880	4.598	5.478
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	48.169	130.690	178.859
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	28:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	26:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	27:15:00	

SSP hydrological data : at 08:00 Hrs on 30-Apr-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 120.92 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13362 Cusec 33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10560 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3736	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4173	3907	6653	580



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

AEE (EMC)  
NCA, INDORE

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRDC respectively. The details:**

**Unit No.1:18:30 hrs on 29.04.2020 to 5:20 hrs on30.04.2020**