

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 4-Apr-20
 ISSUE TIME: 10:00 Hrs
 FOR DATE : 3-Apr-20

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Apr-20	0:00:00	3-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 04.04.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Apr-20	0:00:00	3-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	3-Apr-20	2:00:00	3-Apr-20	24:00:00	22:00:00	39.00	0.847	
4	3-Apr-20	0:00:00	3-Apr-20	24:00:00	24:00:00	38.00	0.936	
5	3-Apr-20	00:00 17:30	3-Apr-20	10:00 24:00	16:30:00	39.00	0.609	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Apr-20	5:30:00	3-Apr-20	8:15:00	2:45:00	185	0.510	Today(i.e. 04.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	3-Apr-20	5:45:00	3-Apr-20	8:30:00	2:45:00	185	0.504	
3	3-Apr-20	5:15:00	3-Apr-20	8:45:00	3:30:00	185	0.644	
4	3-Apr-20	0:00:00	3-Apr-20	0:00:00	0:00:00	0	0.000	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
5	3-Apr-20	0:00:00	3-Apr-20	0:00:00	0:00:00	0	0.000	
6	3-Apr-20	5:00 15:30	3-Apr-20	9:00 18:00	6:30:00	185	1.206	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.392	2.864	5.256
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		6.997	8.596	15.593
PREVIOUS DAY ACTUAL RUNNING HOURS		62:30:00	15:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	15:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	14:30:00	

SSP hydrological data : at 08:00 Hrs on 4-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.87 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11108 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17905 Cusec 44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13264	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	13445	14096	3809	609



Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1:17:50 hrs on 03.04.2020 to 5:00 hrs on 04.04.2020.

Unit No.2:17:55 hrs on 03.04.2020 to 5:05 hrs on 04.04.2020.