

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 5-Apr-20
 ISSUE TIME: 10:00 Hrs
 FOR DATE: 4-Apr-20

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Apr-20	0:00:00	4-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 04.04.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Apr-20	0:00:00	4-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	4-Apr-20	0:00:00	4-Apr-20	24:00:00	24:00:00	39.00	0.923	
4	4-Apr-20	0:00:00	4-Apr-20	24:00:00	24:00:00	40.00	0.955	
5	4-Apr-20	00:00 17:00	4-Apr-20	09:30 24:00	16:30:00	39.00	0.616	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Apr-20	6:00:00	4-Apr-20	8:30:00	2:30:00	183	0.460	Today(i.e. 04.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	4-Apr-20	6:15:00	4-Apr-20	8:45:00	2:30:00	184	0.462	
3	4-Apr-20	5:45:00	4-Apr-20	9:00:00	3:15:00	185	0.598	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	4-Apr-20	15:30:00	4-Apr-20	19:00:00	3:30:00	183	0.650	
5	4-Apr-20	0:00:00	4-Apr-20	0:00:00	0:00:00	0	0.000	
6	4-Apr-20	5:30:00	4-Apr-20	9:15:00	3:45:00	184	0.690	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.494	2.860	5.354
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		9.491	11.456	20.947
PREVIOUS DAY ACTUAL RUNNING HOURS		64:30:00	15:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	27:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	12:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.78 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12560 Cusec 31 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18618 Cusec 46 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13444	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	13958	14225	4393	606



Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1:18:10 hrs on 04.04.2020 to 4:55 hrs on 05.04.2020.

Unit No.2:19:00 hrs on 04.04.2020 to 5:00 hrs on 05.04.2020.