

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 6-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 5-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Apr-20	0:00:00	5-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 06.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	5-Apr-20	0:00:00	5-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	5-Apr-20	0:00:00 12:30	5-Apr-20	10:00 24:00	21:30:00	39.00	0.803	
4	5-Apr-20	0:00:00	5-Apr-20	24:00:00	24:00:00	40.00	0.917	
5	5-Apr-20	0:00:00	5-Apr-20	24:00:00	24:00:00	39.00	0.894	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Apr-20	6:00 20:15	5-Apr-20	8:30 21:30	3:45:00	188	0.650	Today(i.e. 06.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
2	5-Apr-20	5:45 20:00	5-Apr-20	8:15 21:45	4:15:00	188	0.718	
3	5-Apr-20	5:30 19:45	5-Apr-20	8:00 22:15	5:00:00	184	0.856	
4	5-Apr-20	19:30:00	5-Apr-20	22:00:00	2:30:00	185	0.392	
5	5-Apr-20	0:00:00	5-Apr-20	0:00:00	0:00:00	0	0.000	
6	5-Apr-20	5:15 20:30	5-Apr-20	8:45 22:30	5:30:00	190	0.988	

GROSS GENERATION IN(MUs)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		2.614	3.604	6.218
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		12.105	15.060	27.165
PREVIOUS DAY ACTUAL RUNNING HOURS		69:30:00	21:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	12:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	09:45	

SSP hydrological data : at 08:00 Hrs on 6-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14194 Cusec 35 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20995 Cusec 51 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13957	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	15363	14999	5996	604



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL