

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 8-Apr-20
 ISSUE TIME: 10:00 Hrs
 FOR DATE: 7-Apr-20

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Apr-20	0:00:00	7-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 08.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	7-Apr-20	0:00:00	7-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	7-Apr-20	0:00:00	7-Apr-20	24:00:00	24:00:00	38.00	0.899	
4	7-Apr-20	0:00:00	7-Apr-20	24:00:00	24:00:00	39.00	0.931	
5	7-Apr-20	0:00:12:30	7-Apr-20	9:00:24:00	20:30:00	39.00	0.778	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Apr-20	0:00:00	7-Apr-20	0:00:00	0:00:00	0	0.000	Today(i.e. 08.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	7-Apr-20	6:00:00	7-Apr-20	8:45:00	2:45:00	185	0.502	
3	7-Apr-20	5:45:00	7-Apr-20	9:00:00	3:15:00	185	0.590	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	7-Apr-20	0:00:00	7-Apr-20	0:00:00	0:00:00	0	0.000	
5	7-Apr-20	0:00:00	7-Apr-20	0:00:00	0:00:00	0	0.000	
6	7-Apr-20	5:30:00	7-Apr-20	9:15:00	3:45:00	185	0.688	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.608	1.780	4.388
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	17.445	19.056	36.501
PREVIOUS DAY ACTUAL RUNNING HOURS	68:30:00	9:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	12:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	35:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.69 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15884 Cusec 39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18243 Cusec 45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15507	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14306	15027	3216	603



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

AEE (EMC)
 NCA, INDORE

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.3:18:00 hrs on 07.04.2020 to 5:00 hrs on 08.04.2020.

Unit No.6:17:55 hrs on 07.04.2020 to 5:05 hrs on 08.04.2020.