

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
**(ENERGY MANAGEMENT CENTRE, INDORE)**

ISSUE DATE: 9-Apr-20  
 ISSUE TIME: 10:00 Hrs  
 FOR DATE: 8-Apr-20

Daily Plant Report  
 (00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Apr-20	0:00:00	8-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.04.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	8-Apr-20	0:00:00	8-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	8-Apr-20	0:00:00	8-Apr-20	24:00:00	24:00:00	39.00	0.909	
4	8-Apr-20	0:00:17:00	8-Apr-20	13:20:24:00	20:20:00	40.00	0.788	
5	8-Apr-20	0:00:13:50	8-Apr-20	10:00:24:00	20:10:00	39.00	0.762	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Apr-20	5:30:00	8-Apr-20	8:30:00	3:00:00	184	0.550	Today(i.e. 09.04.2020), 1 SSP-RBPH M/cs are running at 10:00 hrs.
2	8-Apr-20	6:00:00	8-Apr-20	8:45:00	2:45:00	185	0.510	
3	8-Apr-20	6:15:00	8-Apr-20	9:00:00	2:45:00	185	0.508	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	8-Apr-20	0:00:00	8-Apr-20	0:00:00	0:00:00	0	0.000	
5	8-Apr-20	0:00:00	8-Apr-20	0:00:00	0:00:00	0	0.000	
6	8-Apr-20	5:45:00	8-Apr-20	9:15:00	3:30:00	185	0.648	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.459	2.216	4.675
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.904	21.272	41.176
PREVIOUS DAY ACTUAL RUNNING HOURS	64:30:00	12:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	35:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	11:30:00	

SSP hydrological data : at 08:00 Hrs on 9-Apr-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.61 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13993 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19315 Cusec 47 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14306	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14154	14155	5160	601



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRDLC respectively. The details:

Unit No.3:17:50 hrs on 08.04.2020 to 04:25 hrs on 09.04.2020.

Unit No.6:17:45 hrs on 08.04.2020 to 04:20 hrs on 09.04.2020.

AEE (EMC)  
 NCA, INDORE