

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Apr-21	0:00:00	27-Apr-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 28.04.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	27-Apr-21	0:00:00	27-Apr-21	24:00:00	24:00:00	42.00	1.000	
3	27-Apr-21	0:00:00	27-Apr-21	24:00:00	24:00:00	43.00	1.014	
4	27-Apr-21	0:00:00	27-Apr-21	0:00:00	0:00:00	0.00	0.000	
5	27-Apr-21	0:00:00	27-Apr-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Apr-21	5:45 21:15	27-Apr-21	9:15 24:00	6:15:00	202	1.258	Today (i.e. 28.04.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	27-Apr-21	0:00 5:30 21:30	27-Apr-21	1:15 9:00 24:00	7:15:00	202	1.456	
3	27-Apr-21	5:15:00	27-Apr-21	8:45:00	3:30:00	202	0.708	
4	27-Apr-21	5:00:00	27-Apr-21	8:30:00	3:30:00	202	0.712	
5	27-Apr-21	0:00:00	27-Apr-21	0:00:00	0:00:00	0	0.000	
6	27-Apr-21	0:00:00	27-Apr-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.014	4.134	6.148
CUMMULATIVE GROSS GEN. FOR MONTH (Mus)	72.827	83.096	155.923
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	20:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	20:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	21:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Apr-21

DATA RECEIVED FROM FLOOD CELL

· RESERVOIR LEVEL IN Metres	123.42 Mtrs.	
· AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	10944 Cusec	26.78 MCM
· AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	16957 Cusec	41.49 MCM
· GOG WATER REQUIREMENT(Next Day) in Cusec		

HR	GODBOLE
10302	614

· AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
611	0	10302	10804	6153	652



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasar, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:- Nil