



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Apr-21	0:00:00	6-Apr-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 07.04.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	6-Apr-21	0:00:00	6-Apr-21	24:00:00	24:00:00	44.00	1.063	
3	6-Apr-21	0:00:00	6-Apr-21	24:00:00	24:00:00	44.00	1.064	
4	6-Apr-21	00:00 07:00	6-Apr-21	02:00 24:00	19:00:00	45.00	0.847	
5	6-Apr-21	0:00:00	6-Apr-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Apr-21	07:00 14:30	6-Apr-21	10:00 17:15	5:45:00	200	1.178	Today (i.e. 07.04.2021), 0 SSP-RBPH M/c is running at 10:00 hrs. RBPH Unit NO. 6 Under AOH from 26.03.2021
2	6-Apr-21	6:45:00	6-Apr-21	9:45:00	3:00:00	202	0.614	
3	6-Apr-21	0:00:00	6-Apr-21	0:00:00	0:00:00	0	0.000	
4	6-Apr-21	0:00:00	6-Apr-21	0:00:00	0:00:00	0	0.000	
5	6-Apr-21	6:30:00	6-Apr-21	9:30:00	3:00:00	202	0.610	
6	6-Apr-21	0:00:00	6-Apr-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.974	2.402	5.376
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.141	17.504	36.645
PREVIOUS DAY ACTUAL RUNNING HOURS	67:00:00	11:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	63:00:00	16:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	17:45:00	

SSP hydrological data : at 08:00 Hrs on 7-Apr-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10879 Cusec 26.62 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19807 Cusec 48.46 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14988	628

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
618	0	14256	14820	4987	699



जल संचय - जल संयोज

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 18:25 Hrs on 06.04.2021 to 04:50 Hrs on 07.04.2021.

Unit No.5: 18:15 Hrs on 06.04.2021 to 04:55 Hrs on 07.04.2021.

EE (EMC)
NCA, INDORE