



**(CHPH 5X50 MW)**

| Unit No. | START    |          | STOP     |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS   |
|----------|----------|----------|----------|----------|-------------|----------------|-------------------|---|
| 1        | 6-Aug-18 | 0:00:00  | 6-Aug-18 | 0:00:00  | 0:00:00     | 0.00           | 0.000             | Today(i.e. 07.08.18), 1 CHPH M/c is running at 08:00 hrs. |
| 2        | 6-Aug-18 | 0:00:00  | 6-Aug-18 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |
| 3        | 6-Aug-18 | 0:00:00  | 6-Aug-18 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |
| 4        | 6-Aug-18 | 0:00:00  | 6-Aug-18 | 24:00:00 | 24:00:00    | 17.00          | 0.392             |   |
| 5        | 6-Aug-18 | 16:00:00 | 6-Aug-18 | 24:00:00 | 8:00:00     | 17.00          | 0.129             |   |

**(RBPH 6X200 MW)**

| Unit No. | START    |         | STOP     |         | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS   |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             | Today(i.e. 07.08.18), no SSP-RBPH M/c is scheduled. |
| 2        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 3        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 4        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 5        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 6        | 6-Aug-18 | 0:00:00 | 6-Aug-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS)                 | 0.521           | 0.000           | 0.521          |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 3.848           | 0.000           | 3.848          |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 32:00:00        | 0:00:00         |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00        | 0:00:00         |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 24:00:00        | 0:00:00         |                |

SSP hydrological data : at 08:00 Hrs on 7-Aug-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 111.02 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3426 Cusec 8 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5522 Cusec 14 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR   | GODBOLE |
|------|---------|
| 5259 | 621     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR   | CHPH | RBPH | IBPT |
|---------|-----------|------|------|------|------|
| 638     | 0         | 4932 | 5522 | 0    | 0    |



नर्मदा नियंत्रण प्राधिकरण

*[Signature]*  
AEE (EMC)  
NCA, INDORE  
7/8/18

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV Asoj, Dhule-1, Raj-1 & Raj-2, Kasor lines are in service right now.

2. RBPH-SCO Running Detail:-

Unit no.2: 22:05 hrs on 06.08.18 to 06:35 hrs on 07.08.2018