



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Aug-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 18-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Aug-19	16:30:00	18-Aug-19	24:00:00	7:30:00	50.00	0.370	Today(i.e. 19.08.2019), 2 CHPH M/c are running at 10:00 hrs.
2	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	50.00	1.198	
3	18-Aug-19	0:00:00	18-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	50.00	1.198	
5	18-Aug-19	0:00:00	18-Aug-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	195	4.486	Today(i.e. 19.08.2019), Five SSP-RBPH M/cs are running.
2	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	195	4.490	
3	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	197	4.508	
4	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	195	4.514	
5	18-Aug-19	0:00:00	18-Aug-19	24:00:00	24:00:00	196	4.530	
6	18-Aug-19	0:00 21:15	18-Aug-19	9:26 24:00	12:11:00	196	2.224	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.766	24.752	27.518
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	32.809	277.564	310.373
PREVIOUS DAY ACTUAL RUNNING HOURS	55:30:00	132:11:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.80 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 265015 Cusec 648 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 48519 Cusec 119 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11033	555

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
534	189640	11579	11888	36631	247



AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVEDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor and Dhule-1 lines are in service.

2. SCO Mode Running Detail: Nil