



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Aug-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 01-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Aug-19	7:30:00	1-Aug-19	10:35:00	3:05:00	38.00	0.113	Today(i.e. 02.08.2019), 1 CHPH M/c is running at 10:00 hrs.
2	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0.00	0.000	
3	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	1-Aug-19	0:00:00	1-Aug-19	1:00:00	1:00:00	39.00	0.037	
5	1-Aug-19	10:30:00	1-Aug-19	24:00:00	13:30:00	38.00	0.496	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	Today(i.e. 02.08.2019), no SSP-RBPH M/c is scheduled.
2	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	
3	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	
4	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	
5	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	
6	1-Aug-19	0:00:00	1-Aug-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.646	0.000	0.646
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.646	0.000	0.646
PREVIOUS DAY ACTUAL RUNNING HOURS	17:35:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15327 Cusec 37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3326 Cusec 8 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4067	501

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
521	0	2659	3326	0	158



For Archita J. F. Kanungo
EMC (Elect.)
2/8/19 NCA
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 01:30 hrs on 01.08.2019 to 07:15 hrs on 01.08.2019.

Unit No.1: 22:10 hrs on 01.08.2019 to 7:00 hrs on 02.08.2019.

Unit No.3: 22:20 hrs on 01.08.2019 to 6:55 hrs on 02.08.2019.