



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Aug-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Aug-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	50.00	1.198	Today(i.e. 20.08.2019), 2 CHPH M/c are running at 10:00 hrs.
2	19-Aug-19	0:00:00	19-Aug-19	2:00:00	2:00:00	50.00	0.099	
3	19-Aug-19	0:00:00	19-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	50.00	1.200	
5	19-Aug-19	15:30:00	19-Aug-19	23:00:00	7:30:00	50.00	0.372	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	179	3.844	Today(i.e. 20.08.2019), All six SSP-RBPH M/cs are running.
2	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	180	3.824	
3	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	177	3.812	
4	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	181	3.874	
5	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	178	3.890	
6	19-Aug-19	0:00:00	19-Aug-19	24:00:00	24:00:00	180	3.836	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.869	23.080	25.949
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	35.678	300.644	336.322
PREVIOUS DAY ACTUAL RUNNING HOURS	57:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.99 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 281090 Cusec 688 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 49173 Cusec 120 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12041	534

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	207593	11729	11421	37752	250



AEE (EMC)  
NCA, INDORE

*[Signature]*  
20/8/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-1and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil