



सर्दार सरोवर प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Aug-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	52.00	1.200	Today(i.e. 23.08.2019), 3 CHPH M/c are running at 10:00 hrs.
2	22-Aug-19	11:00:00	22-Aug-19	24:00:00	13:00:00	51.00	0.646	
3	22-Aug-19	0:00:00	22-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	22-Aug-19	0:00:00	22-Aug-19	0:00:00	0:00:00	0.00	0.000	
5	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	51.00	1.184	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	202	4.764	Today(i.e. 23.08.2019), All six SSP-RBPH M/cs are running.
2	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	200	4.756	
3	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	201	4.764	
4	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	201	4.790	
5	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	201	4.806	
6	22-Aug-19	0:00:00	22-Aug-19	24:00:00	24:00:00	200	4.762	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		3.030	28.642	31.672
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		44.668	383.514	428.182
PREVIOUS DAY ACTUAL RUNNING HOURS		61:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		64:30:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.40 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 149192 Cusec 365 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 55073 Cusec 135 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12549	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	83726	13019	12730	42343	256



for
AEE (EMC)
23/08/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE