



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Aug-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 25-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	50.00	1.194	Today(i.e. 26.08.2019), 3 CHPH M/c are running at 10:00 hrs.
2	25-Aug-19	0:00:00	25-Aug-19	3:00:00	3:00:00	50.00	0.150	
3	25-Aug-19	0:00:00	25-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	50.00	1.197	
5	25-Aug-19	8:00:00	25-Aug-19	24:00:00	16:00:00	51.00	0.792	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	204	4.648	Today(i.e. 26.08.2019), All six SSP-RBPH M/cs are running.
2	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	203	4.652	
3	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	204	4.660	
4	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	204	4.676	
5	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	203	4.690	
6	25-Aug-19	0:00:00	25-Aug-19	24:00:00	24:00:00	203	4.634	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.333	27.960	31.293
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	54.396	469.768	524.164
PREVIOUS DAY ACTUAL RUNNING HOURS	67:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.75 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 375981 Cusec 920 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 365583 Cusec 894 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13596	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	Overflow
0	308953	14403	14400	42230	261	308953



जस रचत - जस संभत

(Signature)

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil