



નર્મદા નિયંત્રણ સંસ્થા  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Aug-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 26-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	50.00	1.200	Today(i.e. 27.08.2019), 3 CHPH M/c are running at 10:00 hrs.
2	26-Aug-19	0:00:00	26-Aug-19	0:00:00	0:00:00	0.00	0.000	
3	26-Aug-19	0:00:00	26-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	51.00	1.198	
5	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	51.00	1.198	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	191	4.468	Today(i.e. 27.08.2019), All six SSP-RBPH M/cs are running.
2	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	191	4.474	
3	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	192	4.480	
4	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	191	4.532	
5	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	191	4.540	
6	26-Aug-19	0:00:00	26-Aug-19	24:00:00	24:00:00	191	4.474	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.596	26.968	30.564
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	57.992	496.736	554.728
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 472016 Cusec 1155 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 455282 Cusec 1114 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14403	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	Overflow
0	398820	15058	14564	41898	263	398820



*[Signature]*  
27/8/19  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil