



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Aug-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 28-Aug-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 52.00 | 1.198 | Today (i.e. 29.08.2019), 3 CHPH M/c are running at 10:00 hrs. |
| 2 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 51.00 | 1.201 | |
| 5 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 51.00 | 1.201 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|-----------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 191 | 4.534 | Today (i.e. 29.08.2019), All six SSP-RBPH M/cs are running. |
| 2 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 189 | 4.496 | |
| 3 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 193 | 4.562 | |
| 4 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 190 | 4.540 | |
| 5 | 28-Aug-19 | 109:58:05 | 28-Aug-19 | 24:00:00 | 24:00:00 | 190 | 4.582 | |
| 6 | 28-Aug-19 | 0:00:00 | 28-Aug-19 | 24:00:00 | 24:00:00 | 192 | 4.534 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.600 | 27.248 | 30.848 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 65.186 | 550.516 | 615.702 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 72:00:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 48:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 48:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 29-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.23 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 446725 Cusec 1093 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 427448 Cusec 1046 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 15080 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HIR | CHPH | RBPH | Ev. Loss | Overflow |
|---------|-----------|-------|-------|-------|----------|----------|
| 0 | 370627 | 15080 | 14422 | 42399 | 271 | 370627 |



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE

Tausif Ahe
29/08
JEC(EMC)