



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Aug-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 30-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	51.00	1.195	Today(i.e. 31.08.2019), 4 CHPH M/c are running at 10:00 hrs.
2	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	51.00	1.198	
3	30-Aug-19	0:00:00	30-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	30-Aug-19	00:00 12:33	30-Aug-19	12:02 24:00	23:29:00	51.00	1.168	
5	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	51.00	1.188	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.728	Today(i.e. 31.08.2019), All six SSP-RBPH M/cs are running.
2	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.736	
3	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.734	
4	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.762	
5	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.768	
6	30-Aug-19	0:00:00	30-Aug-19	24:00:00	24:00:00	201	4.732	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.749	28.460	33.209
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	73.733	606.690	680.423
PREVIOUS DAY ACTUAL RUNNING HOURS	95:29:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.65 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 176367 Cusec 431 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 139341 Cusec 341 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20074	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	Overflow
0	79175	19288	18742	41424	280	79175



for  
AEE (EMC)  
31/08/19

AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil