



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Aug-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Aug-19	0:00:00	7-Aug-19	24:00:00	24:00:00	49.00	1.165	Today(i.e. 08.08.2019), 1 CHPH M/c is running at 10:00 hrs.
2	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0.00	0.000	
3	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0.00	0.000	
5	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	Today(i.e. 08.08.2019), no SSP-RBPH M/c is scheduled.
2	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	
3	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	
4	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	
5	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	
6	7-Aug-19	0:00:00	7-Aug-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.165	0.000	1.165
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	5.386	0.000	5.386
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Aug-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 64662 Cusec 158 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5401 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5826	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	6495	5401	0	203



[Signature]
AEE (EMC)
NCA, INDORE
9/8/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 22:10hrs on 07.08.2019 to 07:45 hrs on 08.08.2019

Unit No.2: 22:05 hrs on 07.08.2019 to 07:40 hrs on 08.08.2019