



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

Revised

ISSUE DATE: 09-Aug-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 08-Aug-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Aug-19	0:00:00	8-Aug-19	24:00:00	24:00:00	51.00	1.192	Today(i.e. 09.08.2019), 1 CHPH M/c Is running at 10:00 hrs.
2	8-Aug-19	0:00:00	8-Aug-19	0:00:00	0:00:00	0.00	0.000	
3	8-Aug-19	0:00:00	8-Aug-19	0:00:00	0:00:00	0.00	0.000	
4	8-Aug-19	17:00:00	8-Aug-19	21:00:00	4:00:00	51.00	0.198	
5	8-Aug-19	0:00:00	8-Aug-19	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Aug-19	20:40:00	8-Aug-19	24:00:00	3:20:00	200	0.678	Today(i.e. 09.08.2019), all six SSP-RBPB M/cs are running.
2	8-Aug-19	22:45:00	8-Aug-19	24:00:00	1:15:00	200	0.260	
3	8-Aug-19	20:50:00	8-Aug-19	24:00:00	3:10:00	201	0.628	
4	8-Aug-19	22:50:00	8-Aug-19	24:00:00	1:10:00	201	0.226	
5	8-Aug-19	23:05:00	8-Aug-19	24:00:00	0:55:00	201	0.170	
6	8-Aug-19	0:00:00	8-Aug-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	1.390	1.962	3.352
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	6.776	1.962	8.738
PREVIOUS DAY ACTUAL RUNNING HOURS	28:00:00	9:50:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Aug-19

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 131.16 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 275845 Cusec 675 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21613 Cusec 53 MCM
- GOG WATER REQUIREMENT(Next Day) In Cusec

HR	GODBOLE
6910	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	109091	8623	6357	15256	218



[Signature]
AEE(EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNI,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC AREA.

1. 400 KV SSP Asoj, Kasar Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil