



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Aug-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 09-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Aug-20	0:00:00	9-Aug-20	24:00:00	24:00:00	34.00	0.794	Today (i.e. 10.08.2020) 1 SSP-CHPH M/c is running at 10:00 hrs.
2	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	9-Aug-20	12:00:00	9-Aug-20	20:30:00	8:30:00	33.00	0.278	
4	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	Today (i.e. 10.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	
3	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	
4	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	
5	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	
6	9-Aug-20	0:00:00	9-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.072	0.000	1.072
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	16.341	0.000	16.341
PREVIOUS DAY ACTUAL RUNNING HOURS	32:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Aug-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 119.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6940 Cusec 16.98 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6801 Cusec 16.64 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6979	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
618	0	6027	6801	0	139



*Ashish*  
AEE (EMC)  
NCA, INDORE  
10/8/20

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 2.-17:15 hrs on 09.08.2020 to 07:40 Hrs on 10.08.2020.

Unit No 3.-17:25 hrs on 09.08.2020 to 07:45 Hrs on 10.08.2020.