



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Aug-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Aug-20	0:00:00	10-Aug-20	24:00:00	24:00:00	34.00	0.793	Today (i.e. 11.08.2020), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0.00	0.000	
4	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	Today (i.e. 11.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	
3	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	
4	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	
5	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	
6	10-Aug-20	0:00:00	10-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	0.793	0.000	0.793
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	17.134	0.000	17.134
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.47 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7524 Cusec 18.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5050 Cusec 12.36 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
6027	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
647	0	3439	5050	0	139



AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 5: 20:35 hrs on 10.08.2020 to 06:35 Hrs on 11.08.2020.

Unit No 6: 20:45 hrs on 10.08.2020 to 06:40 Hrs on 11.08.2020.

Unit No 3: 02:00 hrs on 11.08.2020 to 07:20 Hrs on 11.08.2020.