



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Aug-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 9:00:00 | 9:00:00 | 33.00 | 0.296 | Today (i.e. 12.08.2020), 0 SSP-CHPH M/c is running at 10:00 hrs. |
| 2 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 11-Aug-20 | 19:00:00 | 11-Aug-20 | 24:00:00 | 5:00:00 | 33.00 | 0.165 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|--|
| 1 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today (i.e. 12.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs. |
| 2 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 11-Aug-20 | 0:00:00 | 11-Aug-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 0.461 | 0.000 | 0.461 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 17.595 | 0.000 | 17.595 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 14:00:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 10:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 12-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.56 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8336 Cusec 20.39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2943 Cusec 7.20 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 3439 | 647 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|------|------|------|----------|
| 620 | 0 | 2968 | 2943 | 0 | 140 |



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 4: 20:35 hrs on 11.08.2020 to 06:55 Hrs on 12.08.2020.

Unit No 5: 20:25 hrs on 11.08.2020 to 07:00 Hrs on 12.08.2020.

Unit No 6: 00:10 hrs on 12.08.2020 to 07:05 Hrs on 12.08.2020.

AEE (EMC)
NCA, INDORE

Tauseef Ak
12/08/2020