



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Aug-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 12-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	33.00	0.000	Today (i.e. 13.08.2020), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0.00	0.000	
4	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	12-Aug-20	0:00:00	12-Aug-20	10:00:00	10:00:00	33.00	0.328	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 13.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	
3	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	
4	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	
5	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	
6	12-Aug-20	0:00:00	12-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.328	0.000	0.328
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	17.923	0.000	17.923
PREVIOUS DAY ACTUAL RUNNING HOURS	10:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	10:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.69 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9809 Cusec 24.00 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2079 Cusec 5.09 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2968	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	2008	2079	0	140



जल संचयन - जल संरक्षण

for Shrawan
13-8-20
JES/EMC/NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 3: 21:30 hrs on 12.08.2020 to 07:55 Hrs on 13.08.2020

Unit No 4:21:35 hrs on 12.08.2020 to 07:50 Hrs on 13.08.2020.

Unit No 5: 17:20 hrs on 12.08.2020 to 06:55 Hrs on 13.08.2020.