



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Aug-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 13-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 14.08.2020), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0.00	0.000	
4	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	13-Aug-20	0:00:00	13-Aug-20	19:00:00	19:00:00	34.00	0.624	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	Today (i.e. 14.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	
3	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	
4	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	
5	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	
6	13-Aug-20	0:00:00	13-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.624	0.000	0.624
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.547	0.000	18.547
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	10:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.97 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18746 Cusec 45.86 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2259 Cusec 5.53 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2008	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
623	0	2082	2259	0	141



for shurba
14.8.20
JEE/EMC, NCA

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 1 : 23:30 hrs on 13.08.2020 to 06:55 Hrs on 14.08.2020

Unit No 3: 23:40hrs on 13.08.2020 to 07:00 on 14.08.2020

Unit No 5 21:00 hrs in 13.08.2020 to 08:35hrs on 14.08.2020

AEE (EMC)
NCA, INDORE