



સર્દાર સારોવાર પ્રાદેશિક  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Aug-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 14-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 14.08.2020), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0.00	0.000	
4	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	14-Aug-20	12:00:00	14-Aug-20	24:00:00	12:00:00	34.00	0.396	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	Today (i.e. 14.08.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	
3	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	
4	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	
5	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	
6	14-Aug-20	0:00:00	14-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.396	0.000	0.396
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.943	0.000	18.943
PREVIOUS DAY ACTUAL RUNNING HOURS	12:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29935 Cusec 73.24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2864 Cusec 7.01 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2032	623

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
606	0	2032	2864	0	143



જલ સંચય - જલ સંચય

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:  
Unit No 2 : 13:35 hrs on 14.08.2020 and continued 15.08.2020  
Unit No 5 : 13:45 hrs on 14.08.2020 and continued 15.08.2020

for Arun  
AEE (EMC)  
NCA, INDORE  
TE (EMC) NCA