



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Aug-20	18:36:00	1-Aug-20	24:00:00	5:24:00	34.00	0.181	Unit No. 1 is available for generation at full MW. Today (i.e. 02.08.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	1-Aug-20	0:00:00	1-Aug-20	24:00:00	24:00:00	35.00	0.792	
4	1-Aug-20	00:00 16:30	1-Aug-20	9:00 24:00	16:30:00	36.00	0.558	
5	1-Aug-20	0:00:00	1-Aug-20	20:30:00	20:30:00	34.00	0.659	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 02.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	
3	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	
4	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	
5	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	
6	1-Aug-20	0:00:00	1-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.190	0.000	2.190
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	2.190	0.000	2.190
PREVIOUS DAY ACTUAL RUNNING HOURS	66:24:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data . at 08:00 Hrs on 2-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5266 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13883 Cusec 34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13018	626

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
609	0	13715	13883	0	140



जल कषण - जल संरक्षण

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.5: 00:10 hrs on 02.08.2020 to 07:25 Hrs on 02.08.2020.

Unit No.6: 00:20 hrs on 02.08.2020 to 07:30 Hrs on 02.08.2020.

for
02/08/20