



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Aug-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 25-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0.00	0.000	CHPH Unit No. 2 is under L/C from 11.08.2020. Today (i.e. 26.08.2020), 0 SSP-CHPH M/c is running at 10:00 hrs.
2	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0.00	0.000	
4	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	25-Aug-20	7:00:00	25-Aug-20	18:00:00	11:00:00	50.00	0.509	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	RBPH Unit No. 6 is under L/C from 17.08.2020. Today(i.e. 26.08.2020), 1 SSP-RBPH M/c is running at 10:00 hrs.
2	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	
3	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	
4	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	
5	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	
6	25-Aug-20	0:00:00	25-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.509	0.000	0.509
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	22.677	0.000	22.677
PREVIOUS DAY ACTUAL RUNNING HOURS	11:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	24:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	48:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 129.65 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 107454 Cusec 262.89 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4133 Cusec 10.11 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1546	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	1302	2091	2042	212



*[Signature]*  
26/8/20  
AEE (EMC)  
NCA, INDORE

Copv to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP: Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2: 04:35 hrs on 26.08.2020 to 07:40 Hrs on 26.08.2020.