



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 02-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Aug-20	0:00:00	2-Aug-20	24:00:00	24:00:00	34.00	0.813	Today (i.e. 03.08.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	2-Aug-20	0:00:00	2-Aug-20	24:00:00	24:00:00	35.00	0.807	
4	2-Aug-20	00:00 22:00	2-Aug-20	14:00 24:00	16:00:00	35.00	0.552	
5	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 03.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	
3	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	
4	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	
5	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	
6	2-Aug-20	0:00:00	2-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.172	0.000	2.172
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.362	0.000	4.362
PREVIOUS DAY ACTUAL RUNNING HOURS	64:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5199 Cusec 12.72 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13817 Cusec 33.80 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13714	609

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
615	0	13735	13817	0	140



जल संचयन - जल संरक्षण

for *Tauseef Ali* 03/08/20

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 ,Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRDC respectively. The details:

Unit No.1: 18:10 hrs on 02.08.2020 to 06:55 Hrs on 03.08.2020.

Unit No.2: 18:20 hrs on 02.08.2020 to 07:00 Hrs on 03.08.2020.