

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Aug-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 31-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	51.00	1.194	Today (i.e. 31.08.2020), 3 SSP-CHPH M/c are running at 10:00 hrs.
2	30-Aug-20	0:00:00	30-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	51.00	1.213	
4	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	53.00	1.218	
5	30-Aug-20	0:00:00	30-Aug-20	3:30:00	3:30:00	50.00	0.170	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	164	3.842	Today (i.e. 31.08.2020), 6 SSP-RBPH M/c are running at 10:00 hrs.
2	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	162	3.828	
3	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	164	3.870	
4	30-Aug-20	0:00:00	30-Aug-20	24:00:00	24:00:00	163	3.842	
5	30-Aug-20	0:00:00	30-Aug-20	1:35:00	16:05:00	163	2.524	
6	30-Aug-20	1:20:00	30-Aug-20	24:00:00	22:40:00	161	3.586	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.795	21.492	25.287
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	32.039	97.838	129.877
PREVIOUS DAY ACTUAL RUNNING HOURS	75:30:00	134:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.58 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1079080 Cusec 2640.05 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 923800 Cusec 2260.14 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
11983	983

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1014	869310	17351	15306	39184	237



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDABhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadodra

AEE (EMC)
NCA, INDORE

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil.