



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Aug-20	0:00:00	3-Aug-20	24:00:00	24:00:00	34.00	0.813	Today (i.e. 04.08.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	3-Aug-20	0:00:00	3-Aug-20	24:00:00	24:00:00	35.00	0.811	
4	3-Aug-20	0:00:00	3-Aug-20	23:00:00	23:00:00	35.00	0.795	
5	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 04.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	
3	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	
4	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	
5	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	
6	3-Aug-20	0:00:00	3-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.419	0.000	2.419
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	6.781	0.000	6.781
PREVIOUS DAY ACTUAL RUNNING HOURS	71:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4267 Cusec 10.44 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13469 Cusec 32.95 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13735	615

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
617	0	13594	13469	0	139



for Poochita Kanungo
4.08.2020
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 12:15 hrs on 03.08.2020 to 06:25 Hrs on 04.08.2020.

Unit No.5: 18:05 hrs on 03.08.2020 to 08:05 Hrs on 04.08.2020.

Unit No.6: 22:15 hrs on 03.08.2020 to 09:05 Hrs on 04.08.2020.