



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Aug-20	0:00:00	4-Aug-20	24:00:00	24:00:00	36.00	0.829	Today (i.e. 05.08.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	4-Aug-20	0:00:00	4-Aug-20	24:00:00	24:00:00	34.00	0.801	
4	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	4-Aug-20	10:00:00	4-Aug-20	24:00:00	14:00:00	34.00	0.466	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 05.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	
3	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	
4	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	
5	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	
6	4-Aug-20	0:00:00	4-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.096	0.000	2.096
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	8.877	0.000	8.877
PREVIOUS DAY ACTUAL RUNNING HOURS	62:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.38 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18918 Cusec 46.28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13525 Cusec 33.09 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13308	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
618	0	13541	13525	0	139



for Archita Kharanga
5-08-2020

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 18:35 hrs on 04.08.2020 to 07:50 Hrs on 05.08.2020.

Unit No.4: 18:25 hrs on 04.08.2020 to 07:55 Hrs on 05.08.2020.

AEE (EMC)
NCA, INDORE