



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Aug-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 08.08.2020) 2SSP-CHPH M/cs are running at 10:00 hrs.
2	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	7-Aug-20	0:00:00	7-Aug-20	24:00:00	24:00:00	34.00	0.792	
4	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	7-Aug-20	0:00:00	7-Aug-20	17:00:00	17:00:00	34.00	0.560	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 08.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	
3	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	
4	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	
5	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	
6	7-Aug-20	0:00:00	7-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.352	0.000	1.352
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	14.011	0.000	14.011
PREVIOUS DAY ACTUAL RUNNING HOURS	41:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11129 Cusec 27.23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6904 Cusec 16.89 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
9966	623

AVERAGE OUTFLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
619	0	7356	6904	0	139



for Asst
AEE (EMC)
NCA, INDORE
8/7/20

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:
Unit No3.-18:15 hrs on 07.08.2020 to 6:25 Hrs on 08.08.2020.