



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Aug-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 08-Aug-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Aug-20	11:55:00	8-Aug-20	24:00:00	12:05:00	33.00	0.393	Today (i.e. 09.08.2020) 1 SSP-CHPH M/c is running at 10:00 hrs.
2	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0.00	0.000	
3	8-Aug-20	0:00:00	8-Aug-20	22:00:00	22:00:00	34.00	0.733	
4	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0.00	0.000	
5	8-Aug-20	8:00:00	8-Aug-20	12:00:00	4:00:00	33.00	0.132	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	Today(i.e. 09.08.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	
3	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	
4	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	
5	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	
6	8-Aug-20	0:00:00	8-Aug-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.258	0.000	1.258
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	15.269	0.000	15.269
PREVIOUS DAY ACTUAL RUNNING HOURS	38:05:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Aug-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8071 Cusec 19.75 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7932 Cusec 19.41 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7355	619

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
618	0	6979	7932	0	139



जल सफल - जल सफल

for  
09/08/20

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No 5.-19:15 hrs on 08.08.2020 to 07:50 Hrs on 09.08.2020.

Unit No 3.-19:25 hrs on 08.08.2020 to 07:45 Hrs on 09.08.2020.