



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Dec-18	0:00:00	11-Dec-18	24:00:00	24:00:00	44.00	1.044	Today(i.e. 12.12.18), 3 CHPH M/cs are running at 10:00 hrs.
2	11-Dec-18	0:00:00	11-Dec-18	9:00:00	9:00:00	44.00	0.395	
3	11-Dec-18	2:00:00	11-Dec-18	24:00:00	22:00:00	44.00	0.940	
4	11-Dec-18	0:00:00	11-Dec-18	24:00:00	24:00:00	46.00	1.086	
5	11-Dec-18	17:30:00	11-Dec-18	24:00:00	6:30:00	43.00	0.280	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	Today(i.e. 12.12.18), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.1 under AOH from 01.12.2018
2	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	
3	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	
4	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	
5	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	
6	11-Dec-18	0:00:00	11-Dec-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.745	0.000	3.745
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	43.399	0.000	43.399
PREVIOUS DAY ACTUAL RUNNING HOURS	85:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Dec-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.56 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9994 Cusec 24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17815 Cusec 44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17936	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
615	0	17996	17815	0	305



जल संचयन - जल संरक्षण

Tauseef
12/12

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj,Kasor,Raj-1, and Dhule-1 lines are in service at 10:00 hrs .

2. SSP SCO Running Details:

Unit No.3: 18:50 hrs on 11.12.18 to 06:20 hrs on 12.12.18.

Unit No.5: 18:55 hrs on 11.12.18 to 06:25 hrs on 12.12.18.

for

AEE (EMC)
NCA, INDORE