



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Dec-18
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Dec-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Dec-18	00:00 16:15	1-Dec-18	12:00 24:00	19:45:00	47.00	0.905	Today(i.e. 02.12.18), 4 CHPH M/cs are running at 10:00 hrs.
2	1-Dec-18	0:00:00	1-Dec-18	24:00:00	24:00:00	48.00	1.112	
3	1-Dec-18	0:00:00	1-Dec-18	24:00:00	24:00:00	49.00	1.088	
4	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0.00	0.000	
5	1-Dec-18	0:00:00	1-Dec-18	24:00:00	24:00:00	47.00	1.087	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	Today(i.e. 02.12.18), no SSP-RBPH M/c is scheduled.
2	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	
3	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	
4	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	
5	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	
6	1-Dec-18	0:00:00	1-Dec-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.192	0.000	4.192
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	4.192	0.000	4.192
PREVIOUS DAY ACTUAL RUNNING HOURS	91:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Dec-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.93 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9182 Cusec 22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20607 Cusec 50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20777	631

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
626	0	21058	20607	0	323



जल संचयन - जल संवर्धन

Arun
22/12/18
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-2, Dhule-1 and Dhule -2 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.2: 19:00 hrs on 30.11.18 to 05:15 hrs on 01.12.18.

Unit No.5: 19:10 hrs on 30.11.18 to 05:45 hrs on 01.12.18.

Unit No.3: 20:05 hrs on 30.11.18 to 05:40 hrs on 01.12.18