



**(CHPH 5X50 MW)**

| Unit No. | START    |         | STOP     |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS   |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 24:00:00 | 24:00:00    | 46.00          | 1.081             | Today(i.e. 04.12.18), 4 CHPH M/cs are running at 10:00 hrs. |
| 2        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 24:00:00 | 24:00:00    | 47.00          | 1.094             |   |
| 3        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 24:00:00 | 24:00:00    | 47.00          | 1.084             |   |
| 4        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 24:00:00 | 24:00:00    | 47.00          | 1.118             |   |
| 5        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |

**(RBPH 6X200 MW)**

| Unit No. | START    |         | STOP     |         | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS   |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             | Today(i.e. 04.12.18), no SSP-RBPH M/c is scheduled.<br>SSP-RBPH Unit no.1 under AOH from 01.12.2018 |
| 2        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 3        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 4        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 5        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 6        | 3-Dec-18 | 0:00:00 | 3-Dec-18 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |

|  |  |  |  |  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|--|--|--|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS)                 |  |  |  |  | 4.377           | 0.000           | 4.377          |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS)   |  |  |  |  | 12.918          | 0.000           | 12.918         |
| PREVIOUS DAY ACTUAL RUNNING HOURS        |  |  |  |  | 96:00:00        | 0:00:00         |                |
| TODAY'S DC (Schedule) Planned (in Hours) |  |  |  |  | 96:00:00        | 0:00:00         |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      |  |  |  |  | 96:00:00        | 0:00:00         |                |

SSP hydrological data : at 08:00 Hrs on 4-Dec-18

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 125.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5156 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21868 Cusec 54 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 21474 | 626     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 628     | 0         | 21474 | 21868 | 0    | 318      |



जल प्राधिकरण

*[Signature]*  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-2, Dhule-1 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.2: 19:15 hrs on 03.12.18 to 05:55 hrs on 04.12.18.

Unit No.5: 19:25 hrs on 03.12.18 to 05:50 hrs on 04.12.18.