



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 24:00:00 | 24:00:00 | 45.00 | 1.065 | Today(i.e. 06.12.18), 3 CHPH M/cs are running at 10:00 hrs. |
| 2 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 24:00:00 | 24:00:00 | 47.00 | 1.077 | |
| 3 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 24:00:00 | 24:00:00 | 46.00 | 1.064 | |
| 4 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 24:00:00 | 24:00:00 | 46.00 | 1.100 | |
| 5 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 06.12.18), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.1 under AOH from 01.12.2018 |
| 2 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 5-Dec-18 | 0:00:00 | 5-Dec-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

CHPH (5 X 50MW)

RBPH (6X200 MW)

SSP(CHPH+RBPH)

| | | | |
|--|----------|---------|--------|
| GROSS GENERATION IN(MUS) | 4.306 | 0.000 | 4.306 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 21.532 | 0.000 | 21.532 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 96:00:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 6-Dec-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.21 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10065 Cusec 25 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21607 Cusec 53 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 21414 | 628 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 631 | 0 | 20424 | 21607 | 0 | 314 |



for Archeta Kawange
6.12.18
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj,Kasor,Raj-1 and Dhule-2 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.3: 19:15 hrs on 05.12.18 to 07:40 hrs on 06.12.18.

Unit No.4: 20:10 hrs on 05.12.18 to 06:20 hrs on 06.12.18.

Unit No.5: 20:40 hrs on 05.12.18 to 06:25 hrs on 06.12.18.