



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Dec-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Nov-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Nov-19	0:00:00	30-Nov-19	24:00:00	24:00:00	16.00	0.353	Today(i.e. 01.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	30-Nov-19	9:30:00	30-Nov-19	24:00:00	14:30:00	15.00	0.211	
3	30-Nov-19	0:00:00	30-Nov-19	24:00:00	24:00:00	51.00	1.201	
4	30-Nov-19	0:00:00	30-Nov-19	24:00:00	24:00:00	51.00	1.212	
5	30-Nov-19	0:00:00	30-Nov-19	24:00:00	24:00:00	51.00	1.190	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Nov-19	6:30 14:00	30-Nov-19	11:00 18:00	8:30:00	204	1.720	Today(i.e. 01.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs.
2	30-Nov-19	6:45:00	30-Nov-19	17:45:00	11:00:00	205	2.238	
3	30-Nov-19	0:00:00	30-Nov-19	0:00:00	0:00:00	0	0.000	
4	30-Nov-19	0:00:00	30-Nov-19	0:00:00	0:00:00	0	0.000	
5	30-Nov-19	00:00 6:15 13:45	30-Nov-19	1:00 11:30 18:30	13:00:00	203	2.672	
6	30-Nov-19	00:00 6:00 22:45	30-Nov-19	2:00 18:15 24:00	15:30:00	205	3.148	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.167	9.778	13.945
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	81.746	257.168	338.914
PREVIOUS DAY ACTUAL RUNNING HOURS	110:30:00	48:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	48:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	47:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.39 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19007 Cusec 47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 28524 Cusec 70 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15484	602

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
606	0	16999	15727	12797	620



जल नियंत्रण - जल संयंत्र

for
AEE (EMC)
01/12/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE