

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Dec-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 09-Dec-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Dec-19	0:00:00	9-Dec-19	24:00:00	24:00:00	16.00	0.365	Today(i.e. 10.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	9-Dec-19	0:00:00	9-Dec-19	24:00:00	24:00:00	16.00	0.356	
3	9-Dec-19	0:00:00	9-Dec-19	24:00:00	24:00:00	52.00	1.231	
4	9-Dec-19	0:00:00	9-Dec-19	24:00:00	24:00:00	52.00	1.242	
5	9-Dec-19	0:00:00	9-Dec-19	24:00:00	24:00:00	52.00	1.211	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Dec-19	00:00:00	9-Dec-19	0:00:00	0:00:00	0	0.000	Today(i.e. 10.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs.  <u>Unit No. 1 under AOH from 02.12.2019.</u>
2	9-Dec-19	6:15:00	9-Dec-19	11:45:00	5:30:00	204	1.120	
3	9-Dec-19	16:00:00	9-Dec-19	18:00:00	2:00:00	204	0.394	
4	9-Dec-19	6:00 21:45	9-Dec-19	12:00 24:00	8:15:00	204	1.690	
5	9-Dec-19	00:00 05:45 22:00	9-Dec-19	01:00 18:15 24:00	15:30:00	205	3.152	
6	9-Dec-19	00:00 06:30 22:15	9-Dec-19	2:00 18:30 24:00	15:45:00	204	3.196	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	4.405	9.552	13.957
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	39.192	87.346	126.538
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	47:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	49:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	48:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.26 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19234 Cusec 47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30096 Cusec 74 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17727	373

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	17366	16392	13704	542



Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 KV SSP Asoj, Kasor, Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 21:20 hrs on 09.12.2019 to 05:15 hrs on 10.12.2019.

AEE (EMC)  
NCA, INDORE

Issued by: *[Signature]*  
 10/12/19  
 JE (EMC)