



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Dec-19	0:00:00	1-Dec-19	24:00:00	24:00:00	16.00	0.366	Today(i.e. 02.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	1-Dec-19	0:00:00	1-Dec-19	24:00:00	24:00:00	15.00	0.353	
3	1-Dec-19	0:00:00	1-Dec-19	24:00:00	24:00:00	51.00	1.204	
4	1-Dec-19	0:00:00	1-Dec-19	24:00:00	24:00:00	51.00	1.214	
5	1-Dec-19	0:00:00	1-Dec-19	24:00:00	24:00:00	51.00	1.196	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Dec-19	14:30:00	1-Dec-19	17:30:00	3:00:00	206	0.610	Today(i.e. 02.12.2019), 3 SSP-RBPH M/cs are running at 10:00 hrs.
2	1-Dec-19	6:30 14:15	1-Dec-19	10:30 18:00	7:45:00	202	1.574	
3	1-Dec-19	0:00:00	1-Dec-19	0:00:00	0:00:00	0	0.000	
4	1-Dec-19	6:15 20:45	1-Dec-19	10:15 23:45	7:00:00	203	1.424	
5	1-Dec-19	6:00 14:45 21:00	1-Dec-19	11:45 18:15 24:00	12:15:00	206	2.502	
6	1-Dec-19	00:00 5:30 14:00	1-Dec-19	2:00 12:00 24:00	18:30:00	204	3.752	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.333	9.862	14.195
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	4.333	9.862	14.195
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	48:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	47:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	48:30:00	

SSP hydrological data : at 08:00 Hrs on 2-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18055 Cusec 44 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 28885 Cusec 71 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16991	606

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
600	0	16906	15877	13008	573



जल बचत - जल संयोज

*Handwritten signature*  
AEE (EMC)  
NCA, INDORE  
21/12/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

Unit No. 2: 23:35 hrs on 01.12.2019 to 06:35 hrs. on 02.12.2019.

Unit no. 4: 03:40hrs. on 02.12.2019 to 05:50 hrs. on 02.12.2019.