



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Dec-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 19-Dec-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Dec-19	0:00:00	19-Dec-19	24:00:00	24:00:00	17.00	0.388	Today(i.e. 20.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	19-Dec-19	0:00:00	19-Dec-19	24:00:00	24:00:00	15.00	0.352	
3	19-Dec-19	0:00:00	19-Dec-19	24:00:00	24:00:00	51.00	1.201	
4	19-Dec-19	0:00:00	19-Dec-19	24:00:00	24:00:00	51.00	1.208	
5	19-Dec-19	0:00:00	19-Dec-19	24:00:00	24:00:00	51.00	1.184	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Dec-19	00:00:00	19-Dec-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs. <u>Unit No. 1 under AOH from 02.12.2019.</u>
2	19-Dec-19	6:30:00	19-Dec-19	12:15:00	5:45:00	201	1.156	
3	19-Dec-19	0:00:00	19-Dec-19	0:00:00	0:00:00	0	0.000	
4	19-Dec-19	0:00 06:15 15:30 22:15	19-Dec-19	0:45 11:45 18:30 24:00	11:30:00	202	2.350	
5	19-Dec-19	0:00 06:00 14:30 22:00	19-Dec-19	1:00 12:00 18:45 24:00	13:15:00	202	2.694	
6	19-Dec-19	0:00 05:45 21:45	19-Dec-19	01:30 19:15 24:00	17:15:00	204	3.500	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.333	9.700	14.033
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	76.493	185.588	262.081
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	47:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	48:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.80 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5154 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29995 Cusec 73 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16904	536

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
568	0	17135	16823	13172	500



Signature
AEE (EMC)
NCA, INDORE
20/12/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-2 lines are in service.

2. 400 kV SSP Raj-1 line under outage at SSP.

2. SCO Mode Running Detail: Nil