



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Dec-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Dec-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-19	0:00 14:00 18:30	20-Dec-19	11:45 16:30 24:00	19:45:00	17.00	0.315	Today(i.e. 21.12.2019), 4 SSP CHPH M/cs are running at 10:00 hrs. Unit No. 2 under AOH from 20.12.2019.
2	20-Dec-19	0:00:00	20-Dec-19	11:30:00	11:30:00	15.00	0.168	
3	20-Dec-19	0:00 13:45	20-Dec-19	12:00 24:00	22:15:00	50.00	1.093	
4	20-Dec-19	0:00:00	20-Dec-19	24:00:00	24:00:00	51.00	1.220	
5	20-Dec-19	0:00:00	20-Dec-19	24:00:00	24:00:00	50.00	1.180	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-Dec-19	00:00:00	20-Dec-19	0:00:00	0:00:00	0	0.000	Today(i.e. 21.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No. 1 under AOH from 02.12.2019.
2	20-Dec-19	06:30:00 14:45	20-Dec-19	11:45 18:30	9:00:00	204	1.828	
3	20-Dec-19	0:00:00	20-Dec-19	0:00:00	0:00:00	0	0.000	
4	20-Dec-19	0:00 06:15 15:00 22:15	20-Dec-19	0:45 10:15 17:45 24:00	9:15:00	204	1.890	
5	20-Dec-19	0:00 06:00 15:15 22:00	20-Dec-19	1:00 12:00 18:15 24:00	12:00:00	203	2.440	
6	20-Dec-19	0:00 05:45 21:45	20-Dec-19	2:00 19:15 24:00	17:45:00	204	3.600	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.976	9.758	13.734
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	80.469	195.346	275.815
PREVIOUS DAY ACTUAL RUNNING HOURS	101:30:00	48:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	47:15:00	

SSP hydrological data : at 08:00 Hrs on 21-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.64 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8947 Cusec 22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 28726 Cusec 70 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17135	568

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
479	0	15981	15084	13642	495



AEE (EMC)
NCA, INDORE

Dr. Archita Kamuranga
J. E. (Elect.)
EMC, NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2 and Raj-2 lines are in service.

2. 400 kV SSP Raj-1 line under outage at SSP.

2. SCO Mode Running Detail:

Unit No.2: 19:50 hrs on 20.12.2019 to 05:20 hrs on 21.12.2019.