



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Dec-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 21-Dec-19

**(CHPH 5X50 MW)**

| Unit No. | START     |         | STOP      |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS  |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1        | 21-Dec-19 | 0:00:00 | 21-Dec-19 | 24:00:00 | 24:00:00    | 17.00          | 0.378             | Today(i.e. 22.12.2019), 4 SSP CHPH M/cs are running at 10:00 hrs.<br><br>Unit No. 2 under AOH from 20.12.2019. |
| 2        | 21-Dec-19 | 0:00:00 | 21-Dec-19 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |  |
| 3        | 21-Dec-19 | 0:00:00 | 21-Dec-19 | 24:00:00 | 24:00:00    | 51.00          | 1.197             |  |
| 4        | 21-Dec-19 | 0:00:00 | 21-Dec-19 | 24:00:00 | 24:00:00    | 52.00          | 1.207             |  |
| 5        | 21-Dec-19 | 0:00:00 | 21-Dec-19 | 24:00:00 | 24:00:00    | 51.00          | 1.200             |  |

**(RBPH 6X200 MW)**

| Unit No. | START     |                                 | STOP      |                                 | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS  |
|----------|-----------|---------------------------------|-----------|---------------------------------|-------------|----------------|-------------------|--|
| 1        | 21-Dec-19 | 00:00:00                        | 21-Dec-19 | 0:00:00                         | 0:00:00     | 0              | 0.000             | Today(i.e. 22.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs.<br><br>Unit No. 1 under AOH from 02.12.2019. |
| 2        | 21-Dec-19 | 06:30:00<br>14:45               | 21-Dec-19 | 12:00<br>18:15                  | 9:00:00     | 204            | 1.834             |  |
| 3        | 21-Dec-19 | 0:00:00                         | 21-Dec-19 | 0:00:00                         | 0:00:00     | 0              | 0.000             |  |
| 4        | 21-Dec-19 | 00:00<br>6:00<br>22:15          | 21-Dec-19 | 00:45<br>11:45<br>24:00         | 8:15:00     | 204            | 1.690             |  |
| 5        | 21-Dec-19 | 00:00<br>5:45<br>15:00<br>22:00 | 21-Dec-19 | 1:00<br>11:30<br>18:45<br>24:00 | 12:30:00    | 203            | 2.560             |  |
| 6        | 21-Dec-19 | 00:00<br>5:15<br>21:45          | 21-Dec-19 | 2:00<br>19:15<br>24:00          | 18:15:00    | 204            | 3.706             |  |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 3.982           | 9.790           | 13.772         |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 84.451          | 205.136         | 289.587        |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 96:00:00        | 48:00:00        |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00        | 48:00:00        |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 96:00:00        | 47:30:00        |                |

SSP hydrological data : at 08:00 Hrs on 22-Dec-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 134.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8184 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 27968 Cusec 68 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 15981 | 479     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH  | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 490     | 0         | 16138 | 15503 | 12465 | 490      |



जल संचयन - जल संरक्षण

for  
22/12/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Raj-2 lines are in service.

2. 400 kV SSP Raj-1 line under outage at SSP.

3. SCO Mode Running Detail:

Unit No.2: 19:45 hrs on 21.12.2019 to 06:35 hrs on 22.12.2019.

AEE (EMC)  
NCA, INDORE