



**(CHPH 5X50 MW)**

| Unit No. | START     |         | STOP      |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS  |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1        | 22-Dec-19 | 0:00:00 | 22-Dec-19 | 24:00:00 | 24:00:00    | 17.00          | 0.369             | Today(i.e. 23.12.2019), 4 SSP CHPH M/cs are running at 10:00 hrs.<br><br>Unit No. 2 under AOH from 20.12.2019. |
| 2        | 22-Dec-19 | 0:00:00 | 22-Dec-19 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |  |
| 3        | 22-Dec-19 | 0:00:00 | 22-Dec-19 | 24:00:00 | 24:00:00    | 50.00          | 1.195             |  |
| 4        | 22-Dec-19 | 0:00:00 | 22-Dec-19 | 24:00:00 | 24:00:00    | 52.00          | 1.227             |  |
| 5        | 22-Dec-19 | 0:00:00 | 22-Dec-19 | 24:00:00 | 24:00:00    | 51.00          | 1.204             |  |

**(RBPH 6X200 MW)**

| Unit No. | START     |                        | STOP      |                         | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS   |
|----------|-----------|------------------------|-----------|-------------------------|-------------|----------------|-------------------|---|
| 1        | 22-Dec-19 | 00:00:00               | 22-Dec-19 | 0:00:00                 | 0:00:00     | 0              | 0.000             | Today(i.e. 23.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs. |
| 2        | 22-Dec-19 | 14:30:00               | 22-Dec-19 | 19:30:00                | 5:00:00     | 201            | 1.008             |   |
| 3        | 22-Dec-19 | 6:15:00                | 22-Dec-19 | 11:15:00                | 5:00:00     | 202            | 1.008             |   |
| 4        | 22-Dec-19 | 00:00<br>6:00<br>14:45 | 22-Dec-19 | 00:15<br>11:45<br>19:45 | 11:00:00    | 203            | 2.228             |   |
| 5        | 22-Dec-19 | 5:45<br>15:00          | 22-Dec-19 | 12:00<br>20:15          | 11:30:00    | 203            | 2.342             |   |
| 6        | 22-Dec-19 | 00:00<br>5:30          | 22-Dec-19 | 00:30<br>20:30          | 15:30:00    | 204            | 3.142             |   |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 3.995           | 9.728           | 13.723         |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 88.446          | 214.864         | 303.310        |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 96:00:00        | 48:00:00        |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00        | 47:30:00        |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 72:00:00        | 48:15:00        |                |

SSP hydrological data : at 08:00 Hrs on 23-Dec-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 134.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8580 Cusec 21 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 28368 Cusec 69 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 16137 | 490     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH  | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 506     | 0         | 16361 | 15505 | 12863 | 485      |



for  
23/12/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-2 lines are in service.

2. 400 kV SSP Raj-1 line under outage at SSP.

3. SCO Mode Running Detail:

Unit No.2: 20:10 hrs on 22.12.2019 to 06:10 hrs on 23.12.2019.

Unit No. 5: 21:50 hrs on 22.12.2019 to 06:05 hrs on 23.12.2019.

AEE (EMC)  
NCA, INDORE