



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Dec-19	0:00:00	3-Dec-19	24:00:00	24:00:00	16.00	0.361	Today(i.e. 04.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	3-Dec-19	0:00:00	3-Dec-19	24:00:00	24:00:00	15.00	0.355	
3	3-Dec-19	0:00:00	3-Dec-19	24:00:00	24:00:00	51.00	1.202	
4	3-Dec-19	0:00:00	3-Dec-19	24:00:00	24:00:00	51.00	1.209	
5	3-Dec-19	0:00:00	3-Dec-19	24:00:00	24:00:00	50.00	1.196	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Dec-19	00:00:00	3-Dec-19	0:00:00	0:00:00	0	0.000	Today(i.e. 04.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs. Unit No. 1 under AOH from 02.12.2019. ←
2	3-Dec-19	14:30:00	3-Dec-19	18:15:00	3:45:00	202	0.758	
3	3-Dec-19	00:00 06:00 14:45 21:45	3-Dec-19	01:00 10:15 18:00 24:00	10:45:00	206	2.180	
4	3-Dec-19	5:45:00	3-Dec-19	12:00:00	6:15:00	205	1.276	
5	3-Dec-19	06:15 22:00	3-Dec-19	17:45 24:00	13:30:00	202	2.732	
6	3-Dec-19	00:00 05:30 15:00 21:30	3-Dec-19	02:00 11:45 18:30 24:00	14:15:00	205	2.916	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.323	9.862	14.185
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	12.978	29.282	42.260
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	48:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	48:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	48:15:00	

SSP hydrological data : at 08:00 Hrs on 4-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11587 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 28763 Cusec 70 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16818	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	16844	15908	12855	564



Arjun
AEE (EMC)
NCA, INDORE
4/12/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 18:45 hrs on 03.12.2019 to 05:45 hrs on 04.12.2019.

Unit No.4: 20:40 hrs on 03.12.2019 to 05:40 hrs on 04.12.2019.