



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Dec-19	0:00:00	4-Dec-19	24:00:00	24:00:00	16.00	0.356	Today (i.e. 05.12.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	4-Dec-19	0:00:00	4-Dec-19	24:00:00	24:00:00	15.00	0.351	
3	4-Dec-19	0:00:00	4-Dec-19	24:00:00	24:00:00	51.00	1.201	
4	4-Dec-19	0:00:00	4-Dec-19	24:00:00	24:00:00	51.00	1.214	
5	4-Dec-19	0:00:00	4-Dec-19	24:00:00	24:00:00	51.00	1.194	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Dec-19	00:00:00	4-Dec-19	0:00:00	0:00:00	0	0.000	Today (i.e. 05.12.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs. <u>Unit No. 1 under AOH from 02.12.2019.</u>
2	4-Dec-19	6:15:00	4-Dec-19	18:30:00	12:15:00	204	2.480	
3	4-Dec-19	15:15:00	4-Dec-19	17:45:00	2:30:00	202	0.508	
4	4-Dec-19	6:00 14:30 21:45	4-Dec-19	12:45 18:00 24:00	12:30:00	204	2.556	
5	4-Dec-19	0:00 5:45 15:30	4-Dec-19	1:00 10:45 18:15	8:45:00	205	1.788	
6	4-Dec-19	00:00 05:30 14:00 21:15	4-Dec-19	02:00 12:00 15:15 24:00	12:30:00	205	2.528	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.316	9.860	14.176
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.294	39.142	56.436
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	48:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	48:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	47:15:00	

SSP hydrological data : at 08:00 Hrs on 5-Dec-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17093 Cusec 42 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29204 Cusec 71 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16844	280

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	16673	15902	13302	560



जल बचत - जल संयम

Archita Kawango
J. E. (Elect. Engg)
EMC, NCA
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE (E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
- SCO Mode Running Detail: Nil