



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Dec-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Dec-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Dec-20	0:00:00	10-Dec-20	24:00:00	24:00:00	51.00	1.213	Today (i.e. 11.12.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-Dec-20	0:00:00	10-Dec-20	24:00:00	24:00:00	50.00	1.193	
3	10-Dec-20	0:00:00	10-Dec-20	24:00:00	24:00:00	50.00	1.190	
4	10-Dec-20	0:00:00	10-Dec-20	22:00:00	22:00:00	51.00	1.107	
5	10-Dec-20	00:00:00 17:30	10-Dec-20	08:00:00 24:00	14:30:00	51.00	0.728	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Dec-20	0:00:00	10-Dec-20	0:00:00	0:00:00	0	0.000	Today (i.e. 11.12.2020), 4 SSP-RBPH M/c are running at 10:00 hrs.  Unit No. 1 is under L/C from 01.12.2020
2	10-Dec-20	6:30:00	10-Dec-20	11:15:00	4:45:00	203	0.968	
3	10-Dec-20	7:15:00	10-Dec-20	11:30:00	4:15:00	204	0.864	
4	10-Dec-20	7:00:00	10-Dec-20	11:45:00	4:45:00	203	0.968	
5	10-Dec-20	6:45:00	10-Dec-20	12:00:00	5:15:00	203	1.074	
6	10-Dec-20	0:00:00	10-Dec-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.431	3.874	9.305
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	49.830	31.104	80.934
PREVIOUS DAY ACTUAL RUNNING HOURS	108:30:00	19:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	19:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	19:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.49 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 26197 Cusec 64.09 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25720 Cusec 62.93 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21258	611

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
615	0	21108	20146	5574	477



*[Signature]*  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.3: 19:45 Hrs on 10.12.2020 to 06:15 Hrs on 11.12.2020.

Unit No.2: 19:55 Hrs on 10.12.2020 to 06:10 Hrs on 11.12.2020