



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Dec-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 13-Dec-20

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Dec-20	22:00:00	13-Dec-20	24:00:00	2:00:00	51.00	0.102	Today (i.e. 14.12.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-Dec-20	0:00:00	13-Dec-20	24:00:00	24:00:00	51.00	1.210	
3	13-Dec-20	0:00:00	13-Dec-20	24:00:00	24:00:00	50.00	1.200	
4	13-Dec-20	0:00:00	13-Dec-20	0:00:00	0:00:00	0.00	0.000	
5	13-Dec-20	6:00:00	13-Dec-20	24:00:00	18:00:00	52.00	0.891	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Dec-20	0:00:00	13-Dec-20	0:00:00	0:00:00	0	0.000	Today (i.e. 14.12.2020), 3 SSP-RBPH M/c are running at 10:00 hrs.  Unit No. 1 is under L/C from 01.12.2020
2	13-Dec-20	7:15:00	13-Dec-20	12:00:00	4:45:00	205	0.970	
3	13-Dec-20	7:00:00	13-Dec-20	11:45:00	4:45:00	205	0.968	
4	13-Dec-20	6:30:00	13-Dec-20	11:45:00	4:45:00	204	0.976	
5	13-Dec-20	0:00:00	13-Dec-20	0:00:00	0:00:00	0	0.000	
6	13-Dec-20	6:45:00	13-Dec-20	11:30:00	4:45:00	205	0.972	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.403	3.886	7.289
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	61.340	42.766	104.106
PREVIOUS DAY ACTUAL RUNNING HOURS	68:00:00	19:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	15:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Dec-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 24196 Cusec 59.20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21184 Cusec 51.83 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13516	640

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
612	0	16085	15645	5539	478



AEE (EMC)  
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 18:15 Hrs on 13.12.2020 to 06:05 Hrs on 14.12.2020.

Unit No.3: 18:25 Hrs on 13.12.2020 to 06:00 Hrs on 14.12.2020.